



May 16, 2007

ANTIGO BLOCK CO., INC.
CAL WICK
230 MILTON ST.
PO BOX 34
ANTIGO WI 54409

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: ANTIGO BLOCK CO., INC.
Product Name: BIOMICROBICS HIGH STRENGTH FAST AND MICRO FAST
Model Number(s): ABC 1500 BIO (1.0 AND 1.5 HIGH STRENGTH FAST, 0.5, 0.9, AND 1.5 MICRO FAST)
Product File No: 20070219

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2012.

This approval supersedes the approval issued on December 2, 2002, under product file number 20020374.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020374.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This product is approved to use the following:
 - Dual inlets at end of tank with one access opening above both inlets.
 - Bottom openings for pump and holding tanks.
 - Four inch discharge opening in riser.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp., or Fernco gasket model 44 V-405.
 - Four or six inch PVC coupling cast in the tank or cover wall for connection of inlet, outlet, observation or vent pipe.
 - TUF-TITE Round Riser System to be installed in accordance with the product approval issued to TUF-TITE.
- This tank must be designed to withstand the pressures to which it will be subjected.

ANTIGO BLOCK CO., INC.

Page 2

May 16, 2007

Product File No. 20070219

- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov