



May 24, 2007

JOHNSON DIVERSEY  
VAN WALTER  
1326 WILLOW RD MS# 492  
STURTEVANT WI 53177

Re: Description: PROPORTIONER  
Manufacturer: JOHNSON DIVERSEY  
Product Name: TIME MIZER III  
Model Number(s): 04352 AND 04381  
Product File No: 20070245

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2012.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed downstream of a Watts Anti-Siphon, Spill Resistant, Vacuum Breaker model 008PCQT. The critical level mark on the 008PCQT must be at least 12 inches higher than the chemical injection point of the TimeMizer III and the highest intended use of the spray hose.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov