



June 11, 2007

DICKINSON HOMES, INC.
DALE BORNTRAGER
PO BOX 2245
KINGSFORD MI 49801

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: DICKINSON HOMES, INC.
Product Name: RISER #34 28'X48' CHALET
Model Number(s): #052207
Product File No: 20070255

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2012.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use a department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- The maximum water supply fixture units (wsfu) on Type M copper tubing must not exceed 112.0 wsfu for 1-1/2-inch tubing, 62.0 wsfu for 1-1/2-inch tubing, 34.0 wsfu for 1-inch tubing, 18.0 wsfu for 3/4-inch tubing and 7.5 wsfu for 1/2-inch tubing.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov