



June 20, 2007

DALMARAY CONCRETE PRODUCTS, INC
AARON AUSEN
405 S ARCH ST
JANESVILLE WI 53548

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: DALMARAY CONCRETE PRODUCTS, INC
Product Name: SEPTIC, HOLDING, PUMP OR SIPHON
Model Number(s): 1000 LOW PROFILE
(36.0" L.L., 29.4 GAL/IN., 108" MAX. DEPTH OF BURY, 497 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20070280

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2010.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Four-inch opening located in interior wall and between a distance of 9-inches below liquid level and above 1/3 of liquid level above bottom of tank for septic tanks only.
 - Four or eight-inch opening in tank or access cover.
 - Six-inch inlet and outlet openings.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Dual 4" four inch inlets and/or outlets.
 - Four-inch discharge opening in riser.
 - Three-inch schedule 40 PVC cast in riser for electrical wiring.
 - Cast-A-Seal and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover, access cover or interior wall.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on 06/27/2005 under product file number 20050045.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050045.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov