



July 2, 2007

SLUDGEHAMMER GROUP LTD.  
DR. DANIEL WICKMAN  
336 S DIVISION RD  
PETOSKEY MI 49770

Re: Description: CHEMICAL OR PHYSICAL RESTORATION FOR POWTS  
Manufacturer: SLUDGEHAMMER GROUP LTD.  
Product Name: SLUDGEHAMMER  
Model Number(s): S-46 AND S-86  
Product File No: 20070326

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2010.

This approval supersedes the approval issued on January 17, 2007, under product file number 20070042.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070042.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be utilized in accordance with the manufacturer's printed installation instructions and this product approval. If there is a conflict between the manufacturer's installation instructions and the product approval, the product approval requirements will take precedence.
- The elevation of the system's infiltrative surface must be above the estimated highest groundwater elevation or bedrock by the distance prescribed in column entitled "Fecal Coliform >10000 cfu/100 ml" in Table Comm 83.44-3, Wis. Adm. Code.
- A copy of this approval letter and the manufacturer's printed installation instructions must be supplied to the buyer of this product.
- The outlet baffle of the septic tank, which has this product installed, must have installed an effluent filter capable of filtering particles of 1/8 inch in size or larger.
- This product must be installed by a properly licensed plumber.
- A state Sanitary Permit must be obtained when this product is installed.
- This product must be maintained at least annually.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov  
SBD-10564-E (N.10/97)