



September 6, 2007 REVISED II

PROCON
PREMIER CONCRETE, INC
MIKE DONOHUE
8431 HIGHWAY 57
BAILEYS HARBOR WI 54202

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: PROCON
Product Name: 3 COMPARTMENT SEPTIC/SEPTIC/PUMP
Model Number(s): PROCON 1011/332/757
(41/41/39" L.L., 25.34/8.2/19.85 GAL/IN., 96" MAX. DEPTH OF BURY, 1005 G.P.D. WHEN USED AS A SEPTIC/SEPTIC/SEPTIC TANK OR 643 G.P.D. WHEN USED AS A SEPTIC/SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20070415

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of September 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- This tank must be designed to withstand the pressures to which it will be subjected.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov