



January 30, 2008

PFS CORPORATION
RON H REINDL
1507 MATT PASS
COTTAGE GROVE WI 53527

VERTICALWORKS, INC.
JOHN BAUERLE
3834 PUETZ RD
OAK CREEK WI 53154

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: VERTICALWORKS, INC.
Product Name: MODULAR HOME-PLUMBING TREES
Model Number(s): WATER CLOSETS:WC-00A,WC-00B,WC-00C,WC-00D,WC-00E
KS-00A,KS-00B,KS-00C,KS-00D
WATER:LAV-00A,KS-00B,KS-00C,KS-00D
Product File No: 20070549

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 20 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov