

January 29, 2008

AL'S CONCRETE PRODUCTS, INC.  
CHARLES MACH  
800 TOWNHALL ROAD  
LA CRESCENT MN 55947

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: AL'S CONCRETE PRODUCTS, INC.  
Product Name: SEPTIC/PUMP, SEPTIC/SEPTIC/PUMP, SEPTIC/SEPTIC  
Model Number(s): 1250-750 X LOW 2-COMPARTMENT or 3-COMPARTMENT; 2000 X LOW  
[2- OR OPTIONAL 3-COMPARTMENT  
(34.0" L.L., 22.3 GAL/IN., 96" MAX. DEPTH OF BURY, 941 G.P.D. WHEN USED AS A  
SEPTIC/SEPTIC TANK; 613 G.P.D WHEN USED AS A SEPTIC/PUMP BASED ON A 3  
YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER )  
Product File No: 20080044

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.

**This approval is valid until the end of January 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- This tank must be designed to withstand the pressures to which it will be subjected.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manner that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Four inch discharge opening in riser.
  - Bottom and side pipe openings for siphon, pump and holding tanks.
  - Five inch inlet and outlet openings, with optional six inch openings.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
  - Dual inlets at end of tank with one access opening above both inlets.
  - Dual inlets at end of tank with one access opening above each inlet.
  - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST; Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov