



February 6, 2008

PFS COPORATION
JAMES A ROTHMAN
1570 MATT PASS
COTTAGE GROVE WI 53527

FELSER FOREST PRODUCTS
TED FELSER
N6075 STH 70
WINTER WI 54896

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: FELSER FOREST PRODUCTS
Product Name: NONE
Model Number(s): 24 X 32 AND 24 X 44
Product File No: 20080085

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of November 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 25 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on 11/25/2002 under product file number 20020440.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020440.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov