



June 30, 2008

WADE HYDROMAX
TYLER PIPE
CRAIG AKIN
11910 CR 492
TYLER TX 75706

Re: Description: ROOF DRAIN, SIPHONIC, ALTERNATE PLUMBING SYSTEM
Manufacturer: WADE HYDROMAX
Product Name: WADE HYDROMAX SIPHONIC ROOF DRAIN (team review)
Model Number(s): WH300, WH400, WH500, WH600, WH301, WH401, WH501, WH601, WH300PG,
WH400PG
Product File No: 20080187

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm s. Comm 82.36 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The roof drains must comply with ASME A112.6.9-2005.
- The design and installation of the siphonic roof drain must be in accord with ASPE technical Standard 45.
- All materials must comply with ASPE Technical Standard 45.
- Each siphonic roof drain and gutter drain shall be permanently marked at the dome, bodies, and baffle plates with the manufacturer name or trademark. The baffle plate and drain body shall also be marked with the baffle model number, resistance value, K, and words "REPLACE MISSING BAFFLE WITH MODEL _____." The marking shall be located at a location visible after installation.
- Plans and specification for siphonic roof drain systems must be approved by Department prior to installation of the system.
- Maintenance of the roof shall conform to ASPE Technical Standard 45

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov