



June 18, 2008

ADVANCED DRAINAGE SYSTEMS, INC.
SALES
BRENT A. YEAGER
1814 PINEVIEW DR.
VERONA WI 53593

ADS ADVANCED DRAINAGE SYSTEMS, INC.
MARK KASTI
39W253 SHELDON CT
GENEVA IL 60134

Re: Description: PIPES, POLYETHYLENE
Manufacturer: ADS ADVANCED DRAINAGE SYSTEMS, INC.
Product Name: ADS MEGA GREEN WTIB
Model Number(s): 4" (part # 04650020DW), 6" (part # 06650020DW), 8" (part # 08650020DW), 10" (part # 10650020DW), 12" (part # 12650020IBDW), 15" (part # 15650020IBDW), 18" (part # 18650020IBDW), 24" (part # 24650020IBDW), 30" (part # 30650020IBDW), 36" (part # 36650020IBDW), 42" (part # 42650020IBDW), 48" (part # 48650020IBDW) and 60" (part # 60650020IBDW).
Product File No: 20080196

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) AND 84.30 (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain and vent use(s):
 - a. Storm sewer gravity flow
 - b. Subsoil drain piping gravity flow
- This product shall have a smooth interior and annular exterior corrugations. 4-inch through 60-inch shall meet ASTM F 2648.
- This pipe shall be joined with the MEGA GREEN WT IB joint meeting the requirements of ASTM F 2648 4-inch though 60-inch shall be watertight according to the requirements of ASTM D3212.
- Gaskets shall be made of polyisoprene meeting the requirements of ASTM F477. Gaskets shall be installed by the pipe manufacturer and covered with a removable, protective wrap to ensure the gasket is free from debris. A joint lubricant available from the manufacturer shall be used on the gasket and bell during assembly.
- The pipe shall have a reinforced bell with a bell tolerance device. The bell tolerance device shall be installed by the manufacturer.
- Fittings shall conform to ASTM F2306. Bell and spigot connections shall utilize a spun-on or welded bell and valley, saddle gasket or Mar-Mac coupler.

ADVANCE DRAINAGE SYSTEMS, INC

Page 2

6/18/2008

20080196

This approval supersedes the approval issued on October 26 2007 under product file number 20070460

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070460.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov