

April 28, 2008

SKAW PRE-CAST
JACK SKAW
26255 105TH ST.
NEW AUBURN WI 54757

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: SKAW PRE-CAST
Product Name: SEPTIC/SEPTIC/PUMP, SEPTIC/SEPTIC.SEPTIC, SEPTIC/SEPTIC/SIPHON
Model Number(s): 700/300/600 3 COMPARTMENT
(36" L.L., 17.9/7.7/15.38 GAL/IN., 96" MAX. DEPTH OF BURY, 766.3 G.P.D WHEN USED AS A SEPTIC/SEPTIC/SEPTIC OR 479 G.P.D. WHEN USED AS A SEPTIC/SEPTIC/PUMP BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20080205

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MAY 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
 - Four inch pipe inlet located in the edge of the tank cover.
 - Four inch discharge opening in riser.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Four inch pipe openings located near the bottom of the side or end wall for siphon, pump and holding tanks.
 - Steel locking cover for the access opening.

SKAW PRE-CAST
Page 2
April 28, 2008
PRODUCT FILE NO. 20080205

- Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
- Eight inch threaded plugged opening in access cover.
- Six-inch diameter opening in lower portion of the interior wall for siphon, pump and holding tanks.
- Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- Press Seal "Cast-A-Seal" gasket by Press Seal Gasket Corp.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov