



May 20, 2008

C.E.C.  
DALE SCHLIEVE  
312 CONRO ST  
RHINELANDER WI 54501-3772

ONEIDA CONCRETE PRODUCTS, INC.  
RICK JOHNSON

PO BOX 357  
RHINELANDER WI 54501

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: ONEIDA CONCRETE PRODUCTS, INC.  
Product Name: SEPTIC, HOLDING, PUMP TANKS  
Model Number(s): 1360 LOW PROFILE  
(27 .0" L.L., 50.39 GAL/IN. 72" MAX. DEPTH OF BURY, 651 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20080246

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
  - Press Seal "Cast-A-Seal" gaskets
  - Dual or triple inlets at end of tank with one access or multiple openings above each inlet.
  - Dual or triple outlets end of tank with one access or multiple openings above each outlet.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Tuf-Tite manhole risers and covers, 24" or 30 ".
  - Bottom and side pipe openings for siphon, pump and holding tanks.
  - Four- or six-inch inlet and outlet openings.
  - E-Z Set Risers models 2406, 2412 and 3012 cast in concrete tank cover

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST; Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov