



commerce.wi.gov

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

May 15, 2008

CONTECH CONSTRUCTION PRODUCTS INC.
TODD M. RIEBAU
6441 ENTERPRISE LANE SUITE 116
MADISON WI 53719

CONTECH CONSTRUCTION PRODUCTS,
INC.
DON COLLING, SUPT.
2214 W WISCONSIN ST
PO BOX 236
PORTAGE WI 53901

Re: Description: PIPES AND FITTINGS, ALUMINIZED STEEL (SEE ALSO STORMWATER DETENTION SYSTEMS)
Manufacturer: CONTECH CONSTRUCTION PRODUCTS, INC.
Product Name: CONTECH ULTRA-FLO ALTY2 W/SEAM SEALANT; STORMWATER DETENTION PIPING
Model Number(s): 1" X 1" X 7-1/2" CORRUGATED PIPE AND H-12 DOUBLE BOLT, BAR AND STRAP WITH A BACK UP PLATE AND PROFILE GASKET HUGGER BAND AND O RING GASKETS: 18", 21", 30", 36, 42", 48", 54", 60", 66", 72" AND 78"
Product File No: 20080265

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of February 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This product must conform to American Association of State Highway and Transportation Officials (AASHTO) standard M36/M 36M-90.
- This product may be installed for the following drain and vent use(s):
 - a. Storm sewer gravity flow
- The review undertaken by Commerce staff does not include review and/or approval of this submittal as meeting DNR specifications for ch. NR 151.
- This product is approved for the following use:
 - Stormwater and clearwater subsurface detention system.
- When this product is installed as a subsurface detention system, the installation must be in accordance with the manufacturer's printed instructions. When there is a conflict between the manufacturer's installation instructions and plan approval or product approval stipulations, the plan approval or product approval stipulations will take precedence.

Sizing of piping for stormwater and clearwater subsurface detention shall be made using hydraulic calculations as specified in manufacturer's instructions.

This approval supersedes the approval issued on 2/18/2003 under product file number 20030011. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030011.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov