



July 7, 2008

THERMO ELECTRON CORPORATION  
ANATOMICAL PATHOLOGY/CLINICAL DIAGNOSTIC  
RONALD D.GREEN  
171 INDUSTRY DR.  
PITTSBURGH PA 15275

Re: Description: HEALTH CARE PLUMBING APPLIANCE  
Manufacturer: THERMO ELECTRON CORPORATION  
Product Name: GROSSLAB SENIOR PATHOLOGY WORK STATIONS  
Model Number(s): 9700, 97001, 97002, 97006, 97007, 97008, 970022, 9700122, 9700222, 9700622, 9700722  
and 9700822  
Product File No: 20080297

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.32(4)(b)1.&2. and 84.30(5)(a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

- When this product is installed, registration of the Watts Series 008QT Spill-Resistant Pressure Vacuum Breaker must be made with the department in accordance with s. Comm 82.20 (1)(c) of the Wis. Adm. Code.
- The installation of the flexible fixture drain serving this product must be installed in such a manner that the drain will drain by gravity to the fixture trap serving this product when the product is at any height.
- The fixture trap serving this product must be located as close as practicable and be at least 3" in size.

This approval supersedes the approval issued on June 5 2003 under product file number 20030158.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030158.

This approval does not cover the fixed height models, for they are not required to receive product approval

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: Jerry.Thompson@wi.gov