

December 23, 2008

ROTH GLOBAL PLASTICS, INC.
JOSEPH A BROWN
PO BOX 245
SYRACUSE NY 13211

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: ROTH GLOBAL PLASTICS, INC.
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): RMT-1060
(40" L.L., SEE TABLE 1 FOR GAL/IN., 36" MAX. DEPTH FO BURY, 508 G.P.D. WHEN
USED AS A SEPTIC TANK BASES ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20080357

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JANUARY 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The manhole cover must be secured to the riser using screws which are not standard or phillips head to be considered an effective locking device.
- The tank is not recommended to be installed where saturated soil or seasonal high ground water tables are indicated between the bottom of the tank and the ground surface.
- The tank shall not be buried greater than 36 inches below grade.
- This tank must be set on approximately 6 inches of pea gravel or sand in the bottom of the excavation.
- Backfill material soil shall flow freely into corrugations between tank ribs. The backfill must be compacted in 6 inch lifts.
- This product may be installed using the following inlet/out combinations. End of first compartment to End of second compartment; End first compartment to either Side of second compartment; Either Side first compartment to End of second compartment; Either Side of first compartment to either Side of second compartment.
- When this tank is installed with the optional partition wall, the wall must be installed by the manufacturer and installed in the rib that is located approximately 2/3 of the tank length when measured from the inlet end of the tank.

Table 1 Capacity Chart
ST-1060

Gallons per Inch				
Height (inches)	Gallons in Tank	/ /	Height (inches)	Gallons in Tank
1	10		26	715
2	20		27	750
3	37		28	785
4	55		29	816
5	76		30	847
6	97		31	880
7	120		32	913
8	144		33	947
9	174		34	982
10	203		35	1014
11	234		36	1047
12	265		37	1077
13	294		38	1107
14	323		39	1142
15	356		40	1177
16	390		41	1202
17	423		42	1227
18	457		43	1243
19	488		44	1259
20	520		45	1275
21	552		46	1290
22	584		47	1303
23	618		48	1316
24	653		49	1327
25	684		50	1337

- Tank Bedding: As per manufacturer's instructions, provide min. of 6 inches pea stones free of debris, sharp stones and stones greater than 2 inches in diameter.

This approval supersedes the approval issued on 6/17/2008 under product file number 20080218. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20080218.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov