



August 15, 2008

QUALITY CULVERT INC  
CARL TYNER  
25726 COUNTY ROAD 561  
PO BOX 435  
ASTATULA FL 34705

Re: Description: PIPES, POLYETHYLENE  
Manufacturer: QUALITY CULVERT INC  
Product Name: STORM-SEAL  
Model Number(s): PIPE: TYPE S IN 8", 10", 12", 15", 18", 24", 30", 36", 42" and 48"  
Product File No: 20080445

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (3) (C) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain and vent use(s):
  - a. Storm sewer . . . . . gravity flow
- The pipe must be labeled at intervals of no more than 3.5 meters (11.5 ft) with the manufacturer's name or trademark, nominal pipe size (inches/mm), AASHTO designation (M-252 or M-294), plant designation/code, and date of manufacture.

This approval supersedes the approval issued on August 29 2003 under product file number 20030377.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030377.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: Jerry.Thompson@wi.gov