



September 15, 2008

WIESER CONCRETE PRODUCTS, INC.
MARK WIESER
2815 RILEY ROAD
PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: MBBR (MOVING BED BIOFILM REACTOR)
Model Number(s): WLP 1000/1000/1000-MBBR
(43" L.L., 20.8/18.7/25.0 GAL/IN., 144" MAX. DEPTH OF BURY)
Product File No: 20080489

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of OCTOBER 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product may only be used with the EHS-Environmental / Health Products & Service's Moving Bed Biofilm Reactor System.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030420. This approval supersedes the approval issued on 10/31/2008 under product file number 20030420.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov