



October 30, 2008

WIESER CONCRETE PRODUCTS, INC.  
MARK WIESER  
2815 RILEY ROAD  
PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)  
Manufacturer: WIESER CONCRETE PRODUCTS, INC.  
Product Name: W 1250-MR. NIBBLER JR.  
Model Number(s): W 1250-MR. NIBBLER JR. (NJRG-0002, NJRL-0002, NJRC-0002)  
[96 IN. MAX. DEPTH OF BURY; 47 IN. L.L.; 26.81 GAL./IN.]  
Product File No: 20080493

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- The manhole cover installed above the Nibbler Jr. must be installed so that it terminates at or above grade.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- An access opening having a minimum dimension of 24 inches must be provided over this product.
- The distance from the top of the NIBBLER, Jr. to the top of the access opening must be no more than 24 inches.
- When this product is installed with a NIBBLER Jr. model NJGR-0002, NJRL-0002 or NRJC-0002 in a POWTS in accordance with the manufacturer's recommendations and per the product approval, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
  - Four inch discharge opening in riser.
  - Four inch inlet and outlet openings.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" boot or equal gasket.
  - Optional concrete risers and lids.
  - Manhole riser and cover having a round shape with a minimum 24" inside dimension.

WIESER CONCRETE PRODUCTS, INC.

Page 2

October 30, 2008

PRODUCT FILE NO. 20080493

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov