



May 6, 2010

REVISED COPY

CHICAGO FAUCET CO. / GEBERIT MFG.
LARRY HIMMELBLAU
2100 S. CLEARWATER
DES PLAINES IL 60018

Re: Description: WATER CLOSET, ALTERNATE PLUMBING SYSTEM
Manufacturer: CHICAGO FAUCET CO. / GEBERIT MFG.
Product Name: GEBERIT CONCEALED TANK AND BOWL CARRIER SYSTEM
Model Number(s): 111.335, 111.255, 111.728, 109.304 WATER CLOSET IN-WALL TANK & CARRIER AND
111.625 URINAL CARRIER FRAME. AVAILABLE BOWLS AND URINALS ARE LISTED IN
ATTACHMENT A
Product File No: 20080548

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 82.31 (9) (a) 2. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2015.

This approval supersedes the approval issued on March 11, 2004 under product file number 20040107.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Venting of this product must conform to s. Comm 82.31 (9) (a) 2, Wis. Adm. Code. Fixture drains installed in the vertical position shall be installed in accord with the venting requirements set forth for floor outlet water closets, and the vertical distance between the water level in the bowl and the center line of the horizontal portion of the fixture drain shall not exceed 36-inches as outlined in Comm 82.32 (4) (b) 1.c. Fixture drains installed in the horizontal position shall be subject to venting limitations specified in Comm 82.31 (10).
- This system must be installed in accordance with the manufacturer's printed instructions guide 110.816.00.1.
- Approval is issued for this product as being equivalent to a floor outlet water closet when the fixture drain is installed in the vertical position. The design meets the intent of s. Comm 82.32 (5) (c) and 84.20 (5) (n), Wis. Adm. Code, which requires water closets to discharge through a minimum diameter 3" drain pipe or fitting and the bowl to conform to ANSI Standard A112.19.2M. The intent of the code is met since this product provides the same functional performance as water closets that meet ANSI Standard A112.19.2M.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov