



September 30, 2008

MARSHFIELD WILBERT VAULT WORKS, INC.
JEFFREY RASMUSSEN
PO BOX 493
MARSHFIELD WI 54449

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: MARSHFIELD WILBERT VAULT WORKS, INC.
Product Name: BIO-MICROBICS SINGLE HOME FAST SYSTEM OR MICRO FAST SYSTEM
Model Number(s): 970D
(0.5 or 0.9 MicroFAST)
Product File No: 20080564

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of NOVEMBER 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may ONLY be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- A sedimentation tank or compartment with a minimum capacity of 350 gallons must be located up stream of the tank or compartment in which the Bio-Microbics, Inc., is installed.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

This approval supersedes the approval issued on 12/2/2004 under product file number 20030439. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030439.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

Updated Tank Cross-section. Our records show that the tank cross section(s) on file area at least 10 years old. To update our records, please submit tank cross section(s) with associated dimensions, liquid limits, gallons/inch, bury depths, bedding specs., risers, covers, baffles, etc.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov