



October 2, 2008

APOLLO CORPORATION
STEVE ROKOS
450 MAIN ST
PO BOX 219
SOMERSET WI 54025

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: APOLLO CORPORATION
Product Name: ADVANTAGE TUB
Model Number(s): WP6000, WP6300, AS6000, AS6300
Product File No: 20080566

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The hand held shower and the chemical injection devices must be protected by an ASSE 1014 vacuum breaker or equal.
- A floor drain shall be installed within 6 feet of the tub door.
- When this product discharges waste through indirect waste piping, the waste must discharge to an acceptable receptor in accordance with s. Comm 82.33 (8) of the Wis. Adm. Code.
- Installation and maintenance of this product must be in accordance with the manufacturer's printed installation and maintenance instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

During the period that this product approval is in effect, it is the responsibility of the submitting party to inform Commerce of any changes to the contact information or an address change. **Renewals will be sent to the address of record.**

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov