



October 9, 2008

NORWESCO, INC.
ANASTASIA R. O'HARA
PO BOX 439
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: NORWESCO, INC.
Product Name: 2500 HOLDING
Model Number(s): 42119
2500 GAL. [40 IN. L.L. 24 IN. MAX. DEPTH OF BURY; 2550 GAL. ACTUAL CAPACITY]
Product File No: 20080567

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- This product may not be installed where saturated or seasonal saturated soil conditions exist above the inlet of the tank.
- Bedding: This tank must be bedded in well-compacted sand; 6 in. min. in soil terrain; 12 in. min. in rock terrain.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

NORWESCO, INC.
Page 2
October 9, 2008
PRODUCT FILE NO. 20080567

During the period that this product approval is in effect, it is the responsibility of the submitting party to inform Commerce of any changes to the contact information or an address change. **Renewals will be sent to the address of record.**

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov