



October 13, 2008

DESIGN HOMES, INC.
KURT SMITH
600 N MARQUETTE RD
PO BOX 239
PRAIRIE DU CHIEN WI 53821

Re: Description: **PREFABRICATED PLUMBING SYSTEM**
Manufacturer: **DESIGN HOMES, INC.**
Product Name: **PREFABRICATED PLUMBING**
Model Number(s): **PLB 16**
Product File No: **20080579**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2014.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

This approval supersedes the approval issued on February 6, 2004 under product file number 20030599.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030599.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

During the period that this product approval is in effect, it is the responsibly of the submitting party to inform Commerce of any changes to the contact information or an address change. **Renewals will be sent to the address of record.**

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov