



November 12, 2008

TRI-COUNTY PRECAST, LLC
JAMES F. JOHNSTON
2900 MARY ST
MARINETTE WI 54143

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: TRI-COUNTY PRECAST, LLC
Product Name: FILTER CHAMBER
Model Number(s): 45 GAL. CAPACITY
[for use with Zabel filter models A100, A300 or A1800]
Product File No: 20080616

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.
This approval is valid until the end of November 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When Zabel filter model A100, A300 or A1800 is installed in this tank, installation must be in accordance with the filter manufacturer's printed instructions and the filter's product approval stipulations. If there is a conflict between the filter manufacturer's printed instructions and the filter's product approval stipulations, the product approval stipulations will take precedence.
- The capacity of this filter chamber must not be included in the septic tank capacity required in ch. Comm 83.

This approval supersedes the approval issued on 5/14/2004 under product file number 20040257. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040257

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov