



January 21, 2009

ZOELLER PUMP CO.  
JAY E. COLLINS  
3649 CANE RUN RD  
LOUISVILLE KY 40211

Re: Description: **SEWAGE TREATMENT APPARATUS, TANK/CONTAINER ONLY**  
Manufacturer: ZOELLER PUMP CO.  
Product Name: EFFLUENT FILTER CONTAINER  
Model Number(s): 18 IN. DIA.  
CONTAINER ASSEMBLY w/12" RISER AND LID (#5090-0001), 12" RISER EXTENSION  
w/HARDWARE AND GASKET (#31-1473), 6" RISER; RISER EXTENSION w/HARDWARE  
AND GASKET (#31-1476)  
Product File No: 20090011

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MAY 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- All manhole covers terminating above grade must have effective locking devices.
- **This product must have an approved effluent filter installed on the outlet.**
- A manhole extending to at least 4 inches above finished grade must be provided over the effluent filter.

This approval supersedes the approval issued on 5/12/2004 under product file number 20040133. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040133.

**This product type category has been changed to better reflect it's use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STATC- sewage treatment apparatus, tank/container only.**

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov