

January 28, 2009

SKAW PRE-CAST
JACK SKAW
26255 105TH ST.
NEW AUBURN WI 54757

Re: Description: SEWAGE TREATMENT APPARATUS (see also SEWAGE TANKS; STA-TANK/CONTAINER)
Manufacturer: SKAW PRE-CAST
Product Name: BIOMICROBICS SINGLE HOME FAST®
Model Number(s): 1000 gal.
Product File No: 20090035

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of January 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may only be installed in conjunction with the Bio-Microbics Inc., Single Home Fast sewage treatment apparatus.
- A sedimentation tank or compartment with a minimum capacity of 500 gallons must be located upstream of the tank or compartment in which the Bio-Microbics unit is installed.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

This approval supersedes the approval issued on 2/12/2003 under product file number 20020531. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020531.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

This file has expired on 2/28/2008 and no longer is listed in the Commerce Plumbing Product Register; see http://commerce.wi.gov/php/sb-ppalopp/manuf_alpha_list.php.

Fees were increased on December 1, 2008; see fee due \$25.00..

SKAW PRE-CAST
Page 2
January 28, 2009
PRODUCT FILE NO. 20090035

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov