



February 20, 2009

ADVANCED DRAINAGE SYSTEMS, INC.  
SALES  
BRENT A. YEAGER  
1814 PINEVIEW DR.  
VERONA WI 53593

NYLOPLAST  
ADS INC  
BRENT A. YEAGER  
1814 PINEVIEW DR  
VERONA WI 53593

Re: Description: STORMWATER DRAINAGE, ALTERNATE PLUMBING SYSTEM  
Manufacturer: NYLOPLAST  
Product Name: NYLOPLAST PVC STORM DRAINAGE SYSTEM  
Model Number(s): Drain Basins, Road and Highway structure type inlets basins and Drain Basin/Curb Inlet  
Drain structure type inlets in 8", 10", 12", 15", 18", 24" and 30" diameters.  
Product File No: 20090039

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.35 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in accordance with the manufacturer's printed instructions, system approval, plan approval, and Wis. Adm. Code. If there is a conflict between the manufacturer's instructions and the plan approval, system approval or Wis. Adm. Code, the Wis. Adm. Code, plan approval and system approval will take precedence.
- Location of flow through openings of Drain Basins, Road and Highway structure type inlets basins and Drain Basin / Curb Inlet Drain structure type inlets basins may be at variable elevations and/or locations around the axis of the basin in accordance with manufacturer's specifications noted on drawings numbered 7001-110-012, 7001-110-013, 7001-110-014 entitled 8" and 15" Minimum Angle Between Adapters, 18" and 24" Minimum Angle Between Adapters and 30" Minimum Angle Between Adapters, respectively.
- All connections to storm sewer piping shall be made with the use of watertight adapters.
- All storm sewer materials shall comply with applicable standards referenced in Comm 84 of the Wisconsin Administrative Code.
- When this system is installed without clean outs as required by s. Comm 82.35, Wisconsin Administrative Code, the system must be cleaned by the use of vacuum or jetting system.

This approval supersedes the approval issued on February 17, 2004 under product file number 20030271.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030271.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

ADVANCED DRAINAGE SYSTEMS, INC.

Page 2

February 20, 2009

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: [jerry.thompson@wi.gov](mailto:jerry.thompson@wi.gov)