



March 4, 2009

MIDWAY CONCRETE CORPORATION
NEAL A. LUTZ
P.O. BOX 757
PLOVER WI 54467

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: MIDWAY CONCRETE CORPORATION
Product Name: HOLDING OR PUMP
Model Number(s): **MCC 2500**
(52" L.L. , 49 GAL/IN., 96" MAX. DEPTH OF BURY)
Product File No: 20090104

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of APRIL 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- The products produced by this manufacturer are approved to use the following:
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into the tank cover or manhole in lieu of an observation/vent opening.
 - Optional inlet opening through tank cover using pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover for holding or pump tank use.
 - Bottom openings for holding tank and for pump tank or compartment.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - This product is approved to use Press Seal "Cast-A-Seal" mechanical adapters for all pipe connections.
 - 4" or 6" PVC pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into the inlet and outlet openings of the tank in lieu of hub cast inlet or outlet opening.
 - Dual inlets at end of tank with one access opening above both inlets.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- **Tank bedding: Well-compacted granular material at least 4 in. thick and level at tank corners; center tank shall be 2 in. lower. Materials shall be dry sand or gravel with 100% passing 1/2 in. screen. For wet or in-water installations, set tank on at least 4 in. concrete slab with min. 2 in. bedding material above.**

This approval supersedes the approval issued on 4/28/2004 under product file number 20040172.

MIDWAY CONCRETE CORPORATION
Page 2
March 4, 2009
PRODUCT FILE NO. 20090104

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040172.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov