



March 9, 2009

TECHNICAL CONCEPTS
KEN SENSEL
1310 ALLANSON RD
MUNDELEIN IL 60060

Re: Description: AUTOMATIC URINAL AND TOILET DRIP SYSTEM CLEANER
Manufacturer: TECHNICAL CONCEPTS
Product Name: AUTO CLEAN
Model Number(s): 401188, 401205, 401379 AND 402286
Product File No: 20090114

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The pipe saddle shall be installed at least 6" below critical line of Vacuum Breaker or a Direct Delivery Tube shall be used to maintain the discharge point 6" below critical line of Vacuum Breaker.
- This product must be installed and maintained in accordance with the manufacturer's instructions.

This approval supersedes the approval issued on February 7, 2004 under product file number 20040009.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040009.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov