



June 19, 2009

COUNTY MATERIALS CORP.
BILL MUELLER
PO BOX 100
MARATHON WI 54448

Re: Description: **SEWAGE TREATMENT APPARTUS TANK SYSTEM [SEE STA -SEWAGE TREATMENT APPRATUS]**
Manufacturer: COUNTY MATERIALS CORP.
Product Name: SEPTIC/MICROFAST 0.5, 0.9 AND 1.5 AND SEPTIC/HIGH STRENGTH FAST 1.0 AND 1.5
Model Number(s): 750/1250
[SEE MAX. DWF AND INFLUENT CHARACTERSTICS FOR EACH PRE-TREATMENT UNIT]
Product File No: 20090234

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of SEPTEMBER 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank may only be used when installed with the Bio-Microbics, Inc., High Strength or Micro Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on 9/21/2004 under product file number 20040471.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040471.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

*** This product has been re-categorized (from STA- sewage treatment apparatus to STATS- sewage treatment apparatus tank system) to better describe the actual product approval, which is for a tank which meets the specifications outlined by the manufacturer of the pre-treatment product/device).**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456 E-mail: Jean.MacCubbin@wisconsin.gov