



July 21, 2009

DTR CONCRETE PRODUCTS, LLC  
DUANE ROFFERS  
W 361 COUNTY RD EE  
DE PERE WI 54115

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: DTR CONCRETE PRODUCTS, LLC  
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, or HOLDING  
Model Number(s): 1300 TWO COMPARTMENT (960/348) or 1500 HOLDING, WITH ELBOW IN COVER  
[48 IN. L.L.; 20/7.25 GAL./IN.; 60 IN. MAX. DEPTH OF BURY; 626 GAL. WHEN USED AS  
A SEPTIC/SEPTIC TANK; 460 GAL. WHEN USED AS A SEPTIC/PUMP TANK BASED ON  
A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20090254

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- This product is approved to use the following:
  - Department approved plastic risers and covers installed as required by product approval for the plastic risers and covers with the first riser cast into cover at time of tank production.
  - Conduit hole cast in riser for electrical wiring.
  - Polylok IV High Pressure Pipe Boot Seal by Polylok.
  - Four inch cast iron or schedule 40 ABS or PVC elbow cast in end of cover to create an inlet through the cover when the tank is used as a holing tank.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- TANK BEDDING: Provide 2 to 4 in. of stone no larger than 1 ½ in. or a sand base 2-4 in. thick. Bedding should be rake, not tamped, as to confirm with eh bottom of the tank when settling.

DTR CONCRETE PRODUCTS, LLC  
Page 2  
July 21, 2009  
PRODUCT FILE NO. 20090254

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov