



July 27, 2009

ANDRY RASMUSSEN & SONS, INC.
JEFF RASMUSSEN
42940 USH 63
PO BOX 66
CABLE WI 54821

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: ANDRY RASMUSSEN & SONS, INC.
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 2500
(56 IN. L.L., 45.95 GAL/IN., 108 IN. MAX. DEPTH OF BURY; 1232 G.P.D WHEN USED AS
A SEPTIC TANK BASED ON A 3-YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20090276

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- TANK BEDDING: The bedding for these concrete tanks shall be a 3-inch thick compacted bedding consisting of sand, gravel, granite, limestone or other non-corrosive material that will pass thru a 1/2-inch screen.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040271. This approval supersedes the approval issued on 6/17/2004 under product file number 20040291.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

Company name and address change. Formerly approved under NEECK CONCRETE PRODUCTS

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST, Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov