

July 31, 2009

LEDGEVIEW PRECAST CONCRETE, INC.  
ALLEN E. FREUND  
N6672 COUNTY TRUNK UU  
FOND DU LAC WI 54937

Re: Description: **SEWAGE TREATMENT APPARATUS & TANK SYSTEM [SEE STA -SEWAGE TREATMENT APPARATUS] \***  
Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.  
Product Name: BIO-MICROBICS MICROFAST 0.5, 0.75, 0.9, 1.5 AND HIGH STRENGTH 1.0 AND 1.5  
Model Number(s): 1200  
**[SEE MAX. DWF AND INFLUENT CHARACTERISTICS FOR EACH PRE-TREATMENT UNIT]**  
Product File No: 20090277

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of AUGUST 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may ONLY be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- **Tank bedding and burial depth: A minimum of 4 in. of ¾ in. clear stone overlying a firm uniform base. Bedding should be level around the perimeter and concave at the middle. For tank burial depths greater than 48 in., contact manufacturer for alternate installation instructions.**
- **This approval remains in effect until the expiration date or until the approval of MICRO FAST 0.5, 0.75, 0.9 and 1.5 and HIGH STRENGTH FAST 1.0 and 1.5. are no longer in effect.**

This approval supersedes the approval issued on 1/23/2004 under product file number 20040492.

LEDGEVIEW PRECAST CONCRETE, INC.  
Page 2  
July 31, 2009  
PRODUCT FILE NO. 20090277

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040492.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

**\* This product has been re-categorized (from STA- sewage treatment apparatus to STAS- sewage treatment apparatus tank system) to better describe the actual product approval, which is for a tank which meets the specifications outlined by the manufacturer of the pre-treatment product/device.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov