



August 28, 2009

ACE DURAFLO SYSTEMS, LLC
LARRY GILLANDERS
795 CROMWELL PARK DRIVE SUITE B
GLEN BURNIE MD 21061

ACE DURAFLO SYSTEMS, LLC
LARRY GILLANDERS
1370 REYNOLDS AVE. SUITE 112
IRVINE CA 92614-5546

Re: Description: PIPE LINER
Manufacturer: ACE DURAFLO SYSTEMS, LLC
Product Name: ACE DURAFLO EPOXY
Model Number(s): ADF-204
Product File No: 20090316

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- All aboveground epoxy lined piping must be labeled at intervals of not more than 25 feet and at each side where the piping passes through a wall or floor.
- The label is supplied by Ace Duraflo and contains the following information:
 - Attention! Epoxy Lined Piping All repairs or modifications to this pipe must be carried out using flameless technology following the technical procedures and specifications of ACE DuraFlo Systems, LLC and the epoxy manufacturer.
 - ADF Ace Duraflo the repiping alternative. For more information please call 1-888-775-0220 www.FixMyPipes.com
 - NSF-PW
 - ADF204
 - ACE Duraflo 204 Internal Pipe Coating Process
 - UPC
 - DO NOT REMOVE
- All repairs or modifications to pipe which has been lined with this product must be carried out using flameless technology and following the technical procedures and specifications of ACE DuraFlo Systems, LLC and the epoxy manufacturer.
- This product is limited to piping 1/2 inch in diameter or greater use in pressurized metallic piping systems.

This approval supersedes the approval issued on January 21, 2005 under product file number 20040585.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040585.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov