



September 15, 2009

POLYLOK INC./ZABEL
PETER GAVIN
3 FAIRFIELD BLVD
WALLINGFORD CT 06492

Re: Description: **SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER***
Manufacturer: **POLYLOK INC./ZABEL**
Product Name: A1800 SERIES ZABEL FILTER
Model Number(s): A1800-4x18, A1800-4x18-VT-B35, A1800-4x22-VT-B35, A1800-4x18-VT-B40, A1800-4x22-VT-B40, and A1801-4x22
[MAX. DWF = 800 GPD; 1/16 IN. FILTRATION; FITS 4 IN. OUTLET TEE]
Product File No: 20090317

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JULY 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- The maximum daily wastewater flow, which may discharge through this product, is 800 gallons per day.
- MAINTENANCE: Clean filter at inspection/pumping interval.

This approval supersedes the approval issued on 4/28/2004 under product file number 20040173. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040173.

*** This product type category has been changed to better reflect its use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAF- sewage treatment apparatus, effluent filter only.**

Company name and address change.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov