



October 9, 2009

BRADLEY CORPORATION  
THOMAS R EBERHARDY  
W142 N9101 FOUNTAIN BLVD  
PO BOX 309  
MENONMONEE FALLS WI 53052-0309

Re: Description: FAUCET, LAVATORY  
Manufacturer: BRADLEY CORPORATION  
Product Name: AERADA 900 SERIES FUTURA FAUCET W/ACCUZONE INFRARED CONTROL (AZ)  
Model Number(s): S53-141, S53-148, S53-285, S53-286, S53-186, S53-287, S53-288, 4FTMAR AND  
4FTMAS  
Product File No: 20090348

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.40(4)(c)1.b. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Maximum of four (4) faucets may only be served on one set of shut off valves.

This approval supersedes the approval issued on March 28, 2005 under product file number 20050107.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050107.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov