



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

October 27, 2009

CREST HOMES
CMH MANUFACTURING
LES BALSER
437 N. MAIN STREET
PO BOX 1218
MIDDLEBURY IN 46540

CREST HOMES
CMH MANUFACTURING
BRYAN PROVIDAKES
437 N MAIN ST
PO BOX 1218
MIDDLEBURY IN 46540

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: CREST HOMES
Product Name: Prefabricated Plumbing/ Single fmly Dwelling #981
Model Number(s): SN372059
Product File No: 20090375

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2014.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 33 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The installation of air admittance valves must comply with the Wisconsin Department of Commerce plumbing product approval for the particular valve being installed.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov