

November 16, 2009

SNYDER INDUSTRIES, INC.--SEPTIC
COLE HEAVICAN
4700 FREEMONT ST
PO BOX 4583
LINCOLN NE 68504

SNYDER INDUSTRIES, INC.
CRAIG S WYLER
4700 FREMONT
PO BOX 4583
LINCOLN NE 68504

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: SNYDER INDUSTRIES, INC.
Product Name: 1500 GAL. SEPTIC; SEPTIC/SEPTIC; PUMP; PUMP/PUMP DOMINATOR TANKS
Model Number(s): 1500 GAL. DOMINATOR SEPTIC TANKS
1001510W
(40 IN. L.L.; 36 IN. MAX. DEPTH OF BURY; 586.5 G.P.D. WHEN USED AS A SEPTIC
TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER;
1762 GALS. ACTUAL CAPACITY; TANK DIMENSIONS (ID) = 191 IN. L X 60 IN. W X 51
IN. H; **OPTIONAL 20- AND 24-IN. MANHOLE ACCESS**)
Product File No: 20090385

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30(7)(b) based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of November 2014.**

This alternate approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- Double Chamber: When the optional inter-chamber wall is installed and the tank is used as a double chamber septic/septic, or pump/pump tank, there shall be a separator wall with 5-inch hole through to the second chamber. (The inter-chamber wall is not watertight.) The second chamber shall allow the installation of an effluent filter.
- Labeling: This product includes a permanent embossed marking identifying the following: "SNYDER Industries Inc." (logo and name), maximum burial depth in inches, and maximum capacity in gallons of the tank. The gallon capacity is also the product model. This embossing is located above the inlet.
- Warning: This product includes a cover or septic-lid, embossed with warning label meeting the requirements of s. Comm 84.25(8)(b), Wisc. Admin. Code.
- Burial depth: The maximum burial depth as per the manufacturer is 36 inches.

SNYDER INDUSTRIES, INC.
Page 2
November 16, 2009
PRODUCT FILE NO. 20090385

- The SNYDER INDUSTRIES LOW PROFILE HDPE tanks are no longer sold in Wisconsin; this revision is a replacement to that model.
- This tank is not approved for use as a holding tank as there is no locking apparatus in conformance with s. Comm 84.30 (7)(h), Wisc. Admin. Code.
- See attachments A, B, and C: tank x-section; tank capacity in gal/in. by one-inch increments; Installation Instructions (99800076 rev.).
- Additional information is included as attachment(s) to this letter; see attachment A and B.

This approval supersedes the approval issued 12/2/2008 under product file number 20080533.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov