



November 23, 2009

ZOELLER PUMP COMPANY  
WES COMBS, REGULATORY SPECIALIST  
3649 CANE RUN RD  
LOUISVILLE KY 40211-1961

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER  
Manufacturer: ZOELLER PUMP COMPANY  
Product Name: ZOELLER PRESSURE EFFLUENT FILTER  
**Model Number(s): 5000-0001, 5000-0002 & 5000-0003**  
**[> 1/16 IN. DIA. FILTRATION; 2- AND 3-IN INLET/OUTLET; 100 and 600 micron sock;**  
**SEE MANUFACTURER FOR FILTRATION WITH SOCK]**  
Product File No: 20090400

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of APRIL 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- The maximum daily wastewater flow that may discharge through this product is 375 gallons per day.
- The sizing calculations of the pressure distribution network must include head loss for this product based on flow rate, model and manufacturer pressure loss chart.
- **Additional information is = included as attachment(s) to this letter; see attachment A and B.**

This approval supersedes the approval issued on 4/27/2005 RE-ISSUED 9/10/2009 under product file number 20040629.

ZOELLER PUMP COMPANY  
Page 2  
November 23, 2009  
PRODUCT FILE NO. 20090400

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040629.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov