



January 15, 2010

INFILTRATOR® SYSTEMS INC

DAVID LENTZ
6 BUSINESS PARK RD.
PO BOX 768
OLD SAYBROOK CT 06475

Re: Description: SEWAGE TANK COVERS, LIDS, RISERS
Manufacturer: INFILTRATOR® SYSTEMS INC
Product Name: EZset™ BY INFILTRATOR-- LIDS AND RISERS
Model Number(s): 20 INCH DIAMETER LID, LID-2000; 24 INCH DIAMETER LID, LID-2400;
30 INCH DIAMETER LID, LID-3000; 20 IN DIA. X 6 IN. HT. ACCESS RISER RIS-2006;
20 IN DIA. X 12 IN. HT. ACCESS RISER RIS-2012; 24 IN DIA. X 6 IN. HT. ACCESS RISER
RIS-2406; 24 IN DIA. X 12 IN. HT. ACCESS RISER RIS-2412; 24 IN DIA. X 18 IN. HT.
ACCESS RISER RIS-2418; 30 IN DIA. X 12 IN. HT. ACCESS RISER RIS-3012
Product File No: 20090428

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JUNE 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- All manhole covers terminating above grade must have effective locking devices.
- The manhole cover must be secured to the riser using screws which are not standard or phillips head to be considered an effective locking device.
- The joint between the adapter ring shall be secured to the tank cover with a minimum of six screws and sealed with oxime silicone caulk or butyl mastic sealant.
- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- DESCRIPTION: Stackable risers and lids in 20", 24", and 30" diameters and a variety of heights with slip-resistant, lockable lids to accommodate any new or retrofit installation.

This product was previously approved under the following manufacturer: E-Z Set Company, Inc.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20080292. This approval supersedes the approval issued on 6/12/2008 under product file number 20080292.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov