



February 10, 2010

ORENCO SYSTEMS
NICHOLAS NOBLE
814 AIRWAY AVE
SUTHERLIN OR 97479

Re: Description: SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT
Manufacturer: ORENCO SYSTEMS
Product Name: **18 IN. DIA. EXTERNAL EFFLUENT FILTER BASIN, PVC (WAS 20040200)**
Model Number(s): **FTB 18xx-yyzz**
WHERE xx = basin height, yy = filter diameter, zz = filter cartridge height)
(Variable L.L., volume calculation using 1.06 gal./in., 13 FT. MAXIMUM BURY DEPTH
MEASURED TO BOTTOM OF BASIN)
Product File No: 20100011

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JUNE 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- See Commerce approved effluent filters suitable for insertion:
http://commerce.wi.gov/php/sb-ppalopp/manuf_result.php/988/ORENCO_SYSTEMS_INC#STAFcv

This approval supersedes the approval issued on 9/14/2009 under product file number 20040200. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040200.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov