

October 1<sup>st</sup>, 2010

B & B CHLORINATION  
MIKE BEHRENS  
PO BOX 246  
ALBERT CITY, IA 50510

Re: Description: WATER TREATMENT CHEMICAL INJECTION DEVICE  
Manufacturer: B & B CHLORINATION  
Product Name: DRY PELLET CHLORINATOR  
Model Number(s): MARK 1 AND MARK V  
Product File No: 20100111

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2015.

This approval supersedes the approval issued on March 11<sup>th</sup>, 2005 under product file number 20050001.

This approval is contingent upon compliance with the following stipulation(s):

- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- Only dry chlorine pellets, Environmental Protection Agency Registration number 53026-1, weighing one gram, may be used with this product.
- This product has undergone sufficient testing to document the product's ability to properly inject a chemical into a water supply system as specified in this approval letter.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product to inject a chemical into a water supply system. For more information contact the DNR Private Water Systems Section, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

B&B Chlorination  
October 1<sup>st</sup>, 2010  
Page 2 of 2  
Product File No.: 20100111

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Engineering Consultant-Plumbing Product Reviewer  
Bureau of Integrated Services  
Safety and Buildings Division  
Department of Commerce  
(608) 267-1401 **Phone**  
(608) 267-9566 **Fax**  
glen.schlueter@wi.gov **Email**  
8:00AM – 4:30PM CDT **Work Hours**  
GWS:gws