



June 21, 2010 RE-issued 9/1/2010

Aero-Stream®, LLC
KARL HOLT
W300 N7706 CHRISTINE LANE
HARTLAND WI 53029

Re: Description: CHEMICAL OR PHYSICAL RESTORATION FOR POWTS (CPR)*
Manufacturer: Aero-Stream®, LLC
Product Name: AERO-STREAM
Model Number(s): AS800, AS1000, AS1200, AS1400, AS1600, AS1800
REMIATOR™, PRO LINE™, PRO LINE PLUS™
[SEE SIZING TABLE BASED UPON MAX. BOD5 IN LBS./DAY AND MAX. DWF IN GPD]
Product File No: 20100136

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2015.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be utilized in accordance with the manufacturer's printed installation instructions and this product approval. If there is a conflict between the manufacturer's installation instructions and the product approval, the product approval requirements will take precedence.
- The outlet baffle of the septic tank, which has this product installed, must have installed an effluent filter capable of filtering particles of 1/8 inch in size or larger.
- A state Sanitary Permit must be obtained when this product is installed.
- When this product is installed in a POWTS component, it is considered a modification of the existing POWTS. A state sanitary permit must be obtained when this product is to be installed in a POWTS component. Installation of this product may necessitate evaluation and further modification of the POWTS where this product will be installed. Whichever reviewing agency (governmental unit or state) reviewed and approved the original POWTS plans, shall review the proposed modifications to the existing POWTS.
- A copy of this approval letter and the manufacturer's printed installation and maintenance instructions must be supplied to the buyer of this product and the property owner.
- This product may be installed in an existing POWTS in the following components:
 - . the most downstream sewage treatment tank;
 - . the most downstream sewage treatment tank with an approved effluent filter;
 - . a dose tank;
 - . a distribution box;
 - . a seepage pit.

- Because many Commerce approved products are readily available for sale on the internet; it is important that buyers in Wisconsin are aware of approval stipulations for Commerce-approved products.
For example, in the state of Wisconsin, the installation of this product/device in a POWTS requires a credentialed/licensed person, local or state plan review, and/or the issuance of a state sanitary permit. See applicable codes—chs. Comm 5 and 81-87, <http://commerce.wi.gov/SB/SB-DivCodesListing.html>.
It is recommended that when required (a credentialed/licensed person, plan review and a state sanitary permit), such information is included in written and electronic communications (brochures/advertisements/webpages, etc.) regarding this product/device.
- The elevation of the system's dispersal component infiltrative surface must be above the estimated highest groundwater elevation or bedrock by the distance prescribed in column labeled "Fecal Coliform >10,000 cfu/100 mL" in Table Comm 83.44-3, Wis. Adm. Code.
- When this product is installed in a POWTS component, a properly credentialed/licensed person must perform the installation.
- This product must be installed in sewage treatment tanks that were approved at the time of existing installation and/or currently approved for new/replacement tank installation by the Commerce, Division of Safety and Buildings, for use with this product.
- * **Chemical and Physical Restoration (CPR):** Products approved under this product type by Commerce are only approved for use in existing POWTS systems. (Separate Product Review and Approval are required for design, use and installation in new POWTS.)
- Any and all risers used with the installation of this product/device must have Commerce product approval, s. Comm 84.10.
- A copy of this approval letter must accompany each installation of this product in the State of Wisconsin.
- Additional information is included as attachment(s) to this letter; see attachment A and B.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV