

May 5, 2010

FAIRMONT HOMES INC
CHAD REEVE
502 S OAKLAND AVE
NAPPANEE IN 46550

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: FAIRMONT HOMES INC
Product Name: PFPS TREES
Model Number(s): DWV; A, B, C, D, E, F, G and WATER; TUB/SHOWER, STOOL, CLOTHES WASHER,
KITCHEN SINK, KITCHEN SINK WITH DISHWASHER, and LAVATORY
Product File No: 20100151

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2015.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The installation of air admittance valves must comply with the Wisconsin Department of Commerce plumbing product approval for the particular valve being installed.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

This approval supersedes the approval issued on May 9, 2005 under product file number 20050286.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050286.

A copy of the approved plans and/or specifications is enclosed.

FAIRMONT HOMES INC
Page 2
May 5, 2010
20100151

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov