



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
TTY: Contact Through Relay

Jim Doyle, Governor  
Aaron Olver, Secretary

July 23, 2010

LUMINAIRE  
ELLEN HURST  
301 W. SUPERIOR ST.  
CHICAGO IL 60654

BOFFI  
BARBARA COLOMBO  
VIA GT OBERDAN, 70  
MILANO 20030

Re: Description: FAUCET, BATHTUB OR SHOWER  
Manufacturer: BOFFI  
Product Name: BOFFI PLUMBING FIXTURES  
Model Number(s): **MINIMAL**- MIXER WITH SWINGING SPOUT, FLOOR-MOUNTED UNIT FOR BATH-TUB PROVIDED WITH MIXER, DIVERTER, HAND-SHOWER, SPOUT, BILT-IN MIXER FOR WASH-BASIN AND SHOWER. **RECT06** - BUILT-IN SHOWER AND SPRAY HEAD SYSTEM, WITH DIVERTER, VERTICALLY ASSEMBLED. **RRCT04** - RECESSED WALL CONTAINER FOR TAP, W.1600MM. **Gobi 1** - WASH-BASIN. **RRCT01** - RECESSED WALL CONTAINER FOR TAP. PIPE - BUILT IN MIXER FOR WASHBSIN AND SHOWER, WITH RED HANDLE. FAUCETS AND FITTINGS  
Product File No: 20100166

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.20 (6) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Back flow prevention device shall be installed on all hand held showers..

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov