



May 18, 2010

MARAWOOD CONSTRUCTION SERVICES, INC.
JEREMY BROWN
2025 W VETERANS PARKWAY
MARSHFIELD WI 54449

Re: Description: SEWAGE TANKS, SITE CONSTRUCTED
Manufacturer: MARAWOOD CONSTRUCTION SERVICES, INC.
Product Name: HOLDING TANK
Model Number(s): MCS10000
(90 IN. L.L., 109.7 GAL/IN., 9874 TOTAL GALLONS; TANK DIMENSIONS = 264 IN. L X 96 IN. W X 90 IN. H)
Product File No: 20100210

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of OCTOBER 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- Construction of this product must be designed and constructed in conformance with the specifications submitted and approved by this department and the sealant manufacturer's printed directions for use for the sealant materials.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- **Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ inches screen.**

This approval supersedes the approval issued on 10/6/2005 under product file number 20050696. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050696.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Review
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV