



August 4, 2010

POLYLOK, INC  
PATRICK MULHALL, V.P.  
3 FAIRFIELD BLVD  
WALLINGFORD CT 06459

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER  
Manufacturer: POLYLOK, INC  
Product Name: POLYLOK HIGH PRESSURE EFFLUENT FILTER  
Model Number(s): 3014-PF, 3014-SS  
AVAILABLE AS 1/16 IN. SLOT OR STAINLESS STEEL WITH OPTIONAL 60 OR 100  
MICRON FILTER SOCK FOR PRESSURIZED POWTS SYSTEMS ONLY  
[CLEAN AND MAINTAIN EACH TIME TANK IS PUMP, BUT AT LEAST AT 3-YEAR  
INTERVAL; PROVIDES > 1/16 IN. FILTRATION; MORE FREQUENT REPLACEMENT  
OF FILTER SOCK; **0.5 FT. HEAD LOSS**; MOUNTED DIRECTLY TO DISCHARGE END  
OF ANY PUMP]  
Product File No: 20100290

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- MAINTENANCE: The manufacturer recommends this unit be cleaned every time the tank is pumped or at least once every three years..
- **MAX. 84.6 GPM AT 1.0 PSI FOR FILTER SOCK.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV  
SBD-10564-E (N.10/97)