



December 3, 2010

MOPEC, INC
RICHARD MC CUSKER
21750 COOLIDGE HWY
OAK PARK MI 48237

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: MOPEC, INC
Product Name: ELEVATING GROSSING STATION
Model Number(s): MB600
Product File No: 20100321

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2015.

This approval is contingent upon compliance with the following stipulation(s):

- A Spill Resistant Vacuum Breaker (ASSE 1056) or a Reduced Pressure Principal Backflow Preventer (ASSE 1013) shall be installed serving the hand held hose and spray.
- Supply hoses shall comply with a potable water standard and have a pressure/temperature rating of 100 psi at 180 degrees.
- Flexible drain piping shall have a smooth interior surface.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov