



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor
Aaron Olver, Secretary

September 17, 2010

3M
BCSD
KATHY THOMPSON
BLDG 250-3W-03
ST PAUL MN 55144

RD INDUSTRIES
DAVE KERNES
7417 N 101ST
OMAHA NE 68122

Re: Description: PROPORTIONER
Manufacturer: RD INDUSTRIES
Product Name: 3M PORTABLE DISPENSING SYSTEM
Model Number(s): P10
Product File No: 20100348

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 (3 (a) & 84.20 (5) (d) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in accordance with the manufacturer's published installation instructions.
- The backflow prevention device (ASSE 1011 or 1052) provided shall be used on each faucet that provides water for this device.
- This product must be installed with the pressure indicating tee permanently attached to the inlet of the supply hose serving this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov